

"RCM Database for Process Industry"

(Refineries, Chemical, Petrochemical, Power Plants, Utilities and others)
2020




TABLE OF CONTENTS

TΑ	BLE C	OF CONTENTS2
ΑE	BREV	TATIONS3
1.	INTR	ODUCTION4
	1.1	PURPOSE OF THIS DOCUMENT4
		METHODOLOGY4
	1.3	THE RCM DATABASE STRUCTURE4
2.		HORE EQUIPMENT7
	2.1	ROTATING EQUIPMENT7
	2.1.1 coupli	Pumps (Components: seal, bearing, shaft, impeller, O-ring, casing, packing, shaft, ing, nozzle)
	2.1.2 stator	Motors (Components: shunt, brushes, wires, armature, magnetic frame, packing, shaft, magnets, bearing and winding)
	2.1.3 packii	Centrifugal Compressors (Components: seal, bearing, rotor shaft, impeller, casing, ng, coupling, rotor, gasket, labyrinth, inlet guide vane)
	2.1.4 coupli	Screw Compressor (Components: seal, bearing, Screw rotor, gear, casing, packing, ing and gasket)
	2.1.5 cranks	Reciprocating Compressor (Components: seal, bearing, inlet valve, outlet valve, shaft, packing, casing, connection rod, coupling, piston, piston rod, cylinder and frame) .34
	2.1.6 valve,	Compressor Auxiliaries (Equipment: sensors, controller, Inlet valve, outlet valve, relief gas filter, gear box, piping and cooler)41
	2.1.7 piping	Lubrication Unit (Equipment: oil tank, pump, motor, oil filter, check valve, cooler and g) 48
	2.1.8 blades	Gas turbine (Components: seal, bearing, gear, casing, fuel nozzle, rotor shaft, rotor s) 51
	2.1.9 comp	Turboexpander (Equipment: seal, bearing, casing, nozzle, rotor shaft, expander wheel, ressor wheel and stator)
	2.2	STATIC EQUIPMENT 66
	2.2.1	Vessel (Components: cylinder, head, flange, manhole flange, support)66
	2.2.2	Tank (Components: Tank structure, PSV, Vent, Controls, Sensor, Alarm, gasket, nozzle) 69
	2.2.3	Pipes (Components: pipe structure, joint, gasket, flange)
	2.2.4 bad li	Towers/columns: (Components: demister, trays, liquid distributor, liquid re-distributor, miter, packing, manhole)76
	2.2.5 outlet	Reactors: (Components: Feed diffuser, trays, support grid, mix chamber, collection tray, collector, center pipe, scallops, outer basket, SSR flow, header)79
	2.2.6 dampe	Furnace (Components: burner, firebox, radiant tubes, conventional tubes, refractory, er, stack, pre-heater, air blower)
	2.2.7 nozzle	Air coolers (Components: Tube, motor, fan, fixed header, floating header, support, e) 87
	2.2.8	Heat Exchangers (Components: shell, tube, tie rod & spacer, baffles, tube Sheet, nozzle) 91

REF	EREN	ICES127
	2.4.4 filter, a	Air System (Equipment: compressor, air receiver vessel, air dryer vessel, air dryer pre- ir dryer filter, relief valve, control valve, controller, alarms and instruments, lines) 122
	2.4.3 cooler,	Water System (Equipment: water reservoir, water tower, pump, motor, fan, valve, filter, valves, piping, chillers)
	2.4.2 disjund	Electric System (Equipment: generator, transformer, electric panel, substation, tor, cables, power connection, barr, switch board)
	2.4.1 interna	Boiler System (Equipment: burner, combustion chamber, shell, boiler support, fan, l tube, supply line, export lines, pre-heater, dearator)
2.	4 U	TILITY SYSTEM 108
	2.3.1 shutdo	Safety and Control (Equipment: control valve, relief valve, safety valve, emergency wn valve, valve actuator, sensor, controller, alarm and instruments)
2.	3 S	AFETY AND CONTROL101
	2.2.10	Gas Filters (Components: Internal filter elements, external filter body)98
	2.2.9	Oil Filters (Components: Internal filter elements, external filter body)95

ABBREVIATIONS

2P Two Parameters

ETF Expected Time to Failure

FMEA Failure Mode and Effect Analysis

PDF Probability Density Function

RAM Reliability Availability and Maintainability

1. INTRODUCTION

1.1 PURPOSE OF THIS DOCUMENT

The ECC RCM database aims to provide the maintenance task based on the information of equipment failure modes, cause and effects of oil and gas and petrochemical process plants equipment and component. The RCM database provides a guideline for support projects during concept and design phase and assessment of physical asset during operational phase considering the best maintenance task for each equipment/component failure mode. By using the ECC RCM data base you will have the following:

- To safe time, money and effort by with standardized failure modes, cause and consequences;
- To have the basis for RCM analysis and safe time, money and effort;
- To implement the standardized failure modes, cause and effect in the FRACAS, CMMS, Asset Management systems;
- To safe time, money and effort by with standardized failure modes, cause and consequences in safety and risk analysis;

Based on the equipment / component list defined the RCM is described by using a general risk matrix. In order to update the RCM database by using the different risk matrix, a reassessment must take place.

1.2 METHODOLOGY

The RCM database is based on the Reliability Engineer Expert Dr. Eduardo Calixto experience in hundreds of Reliability Engineering analysis including FMEA and RCM.

However, this RCM database is defined in for equipment and component level. Because of different equipment configuration, it was considered the most critical component that affect the equipment reliability performance.

The RCM data base is presented in level 1 (equipment) and level 2(component).

The main equipment of Oil and gas industry of downstream and upstream are divided in different types of equipment and system such as:

- Rotating;
- Static;
- Safety and Control;
- Utilities.

1.3 THE RCM DATABASE STRUCTURE

The RCM database is structured in a template divided in:

- Equipment List
- Equipment / Component Functions
- Failure Mode

- Cause
- Consequence
- Risk
- Preventive Maintenance

The "Equipment Description" describes the type of equipment, supplier, operation conditions and design specification.

The "Equipment Configuration" describes the number of equipment components in order to clarify if there is redundancy or not.

The "Equipment Function" describes the equipment objective.

The "Component" describes the type of components of the equipment.

The "Component Function" describes the objective of the components.

The "Failure Modes" describes the way that such components lose their function.

The "Failure Mode Causes" describes why failure mode happens.

The "Risk" describes the combination of the occurrence of failure modes cause and effects.

The "Maintenance Task" that aims to mitigate the risk.

The "Type" of Maintenance that defines the type of maintenance such as corrective (Co), Predictive (pdm), Schedule (Sch), Inspection (Insp).

The "Interval" of maintenance that defines the frequency of maintenance task.

The "Risk Post" is the risk mitigated after the preventive maintenance.

The "Phase" describes each phase of an asset when the failure mode happens, based on its cause. The asset phases are described in the RCM sheet as: De (design), Mo (Montage), Tra (Transportation), Ins (Installation), Pred (Pre-Commissioning), Op (Operation).

The "Risk Assessment" on the RCM analysis, is the combination of the likelihood of failure mode with the consequence of failure mode effect, defined in the FMEA. In order to analyze the risk, the qualitative risk assessment was carried out based on specialist opinion. In order to simplify the RCM template, the occurrence and severity classification will not be shown but only the final risk classification.

The "Likelihood Assessment" is the frequency of the failure modes occurrence based on the risk matrix description. The failure modes frequencies classification are in line with the ECC reliability and maintainability database.

There are different configurations of risk matrix and such configuration must reflect the law and companies risk policy. The figure 2 shows an example of risk matrix with four severity categories and six frequency categories.

Figure 2 – Risk Matrix

		FREQUENCY CATEGORY						
		A (extremely remote)	B (remote)	C D (Little frequence)		E (Very frequent)	F (Extremely frequent)	
		At least 1 between 1000 and 100000 years	At least 1 between 50 and 1000	At least 1 betwen 30 and 50 years	At least 1 betwen 5 and 30 years	At least 1 in 5 years	At least 1 in 1 year	
DO 1000 F	2	М	NET	NT	OUT.	NT	NT	
SEVERITY	=	м	М	NT	NT	NT	NT	
SEVE	=	Т	т	М	М	М	М	
	8=1	т	Т	T	М	М	М	

In addition, severity classification must describe all parties affected in the case of an accident like employees, community and environment as well as company installations cost. The figure 3 shows an example of severity category.

Figure 3 – Severity classification

			Description and caracteristic						
			PERSONAL SAFETY	INSTALATION		SOCIAL			
	IV Catastofic		Cathastrofic injures with death, its possible to effect people outside	Losses in equipment and plant with high cost to buy the new one	Loss of ecosystem with bad nacional and international company image reputation	Economics effects in local activities, healh cost in local populatio, economics losses in turism, ecosystem local losses and quality of life losses. (Betwen R\$ 101.000.000,00) and R\$ 336.000.000,00)			
ATEGORY	ш	Critical	Critical injuries. Employees stay a period oftime out of workplace	Equipment serius damaged with high cost to repair	Critical effects to enviroment being hard to improve eosystem condition even with human actions. Bad nacional and international company image reputation	Economics effects in local activities, healh cost in local populatio, economics losses in turism, ecosystem local losses (Betwen R\$ 2.500.000,00 and R\$ 101.000.000,00)			
SEVERITY CATEGORY	II	Marginal	Moderate injuries with firt aid assistence	Low equipment damaged with low repair cost	Not serius enviroment effect but its necessary human intervention and actions to improve enviroment.Bad nacional company image reputation	Economics effects in local activities, healh cost in local population, economics losses in turism, fishing and the others (Form R\$ 0,00 to R\$ 2.500.000,00)			
	1	NOT EFFECT	Theres no injuries and health damaged	There is not damaged to equipment and plant	Insignificant enviroment effect. There is not necessity to human action to ecosystem improvment. There is not nacional company image reputation bad effect	There is not economics effects in local activities, healh cost in local population			

2. ONSHORE EQUIPMENT

2.1 Rotating Equipment



2.1.1 *Pumps* (Components: seal, bearing, shaft, impeller, O-ring, casing, packing, shaft, coupling, nozzle)

The centrifugal pump is one of the most used pumps in Petrochemical, chemical and Oil and Gas industry, therefore, such RCM will describe the main components failure modes, cause, risk and preventive maintenance mitigation action. The first step in RCM analysis is to define the equipment and components list. The main component of centrifugal pump can be described on equipment hierarchy as follows:

- Seal;
- Bearing;
- Shaft;
- Impeller;
- O-ring;
- Casing;
- Packing;
- Shaft;
- Coupling;
- Nozzle.

The next step is to define the equipment and component function, which is described on table 1 below.

Table 1 – Pump equipment and component function (RCM)

Reliability Centred Maintenance (RCM)								
RCM L			Document: DE-xxxx-001 Rev01	Date:xx-xxx-xxxx				
	n: xxxxxxx		Subsystem:	Equipment: P-01 A/B				
N0	Equipment Number	Equipment Description	Equipment Function	Component	Component Function			
1		•		O-ring	Avoid leakage Protect the			
2				Casing	Protect the impeller and create a chamber for the fluid be pumped through.			
3				Coupling	Transmit torque to impeller			
4	P-101 A/B	Centrifugal Pump	Transfer a given liquid at a system required flow rate of "X" and a pressure of "Y"	Impeller	Spin the fluid inside the pump chamber			
5				Shaft	Transmit mechanical energy			
6				Seal	Prevent external leakage			
7				Bearing	Ensure shaft alignment			
8				Packing	Control leakage			
9				Nozzle	To direct or modify the flow of a fluid			

The next step is to perform the different component RCM Analysis as shows the tables 2 below

Table 2 – RCM Pump (O-ring, Casing, and Coupling)

Reliability Centred Maintenance (RCM)										
	// Leader: Eduardo C		Document: DE-xxxxx-001 Rev01			Date:xx-xx-2020				
System: xxxxx				system: x		Equipment: P-01 A/B		Component: O-ring, Casing and Coupling		
N0	Component	Failure mode	Pha se	Cause	R	Maintenance Task	Type	Interval	Risk (Post)	
1			Ор	Aged	EI	Visual Inspection	Sch	2 years	DI	
2			Ор	Excessive solids in fluid causing premature wear	EI	Process control (To control fluid quality)	N/A	N/A	DI	
3	O-ring	Worn out	Ins	Impeller misaligned	EI	Visual Inspection (To verify impeller alignment)	Sch	2 months	DI	
4		Brittle	Ор	Overheat due lack of cooling or adequate liquid flow	EI	Process control (To control fluid quality)	N/A	N/A	DI	
5		Deformation	ОР	Excessive temperature, pressure or chemical attack	EI	Process control (To control fluid temperature)	N/A	N/A	DI	
6			Ор	Normal wear	DI	Visual Inspection	Sch	2 years	CI	
7	Casing	Worn out	Ор	Excessive solids in fluid causing premature wear	DI	Process control (To control fluid quality)	N/A	N/A	CI	
8		Distorted	Ор	Excessive pipe strain caused by overload.	DI	Process control (To control process load)	N/A	N/A	CI	
9	Coupling	oupling Worn out	Ор	Vibration caused by Improper shaft alignment	DII	Visual Inspection (To verify impeller alignment)	Sch	2 months	CII	
10			Ор	Improper lubrication	DII	To control lubricant quality	Sch	1 month	CII	
11			Ор	Normal wear	DII	Visual Inspection	Sch	2 years	CII	